



Tel. No.0755-2586343
Fax No. 0755 – 2587774
Email: cpribpl@sancharnet.in

**CENTRAL POWER RESEARCH INSTITUTE
GOVINDPURA : BHOPAL – 462 023**

PROVISIONAL REPORT

7 JUN 2017

Test Report No. S2170750

Date of test : 7th June, 2017

1. **Customer:** M/s Gmax Electric, Uttam Nagar, Delhi
2. **Sample tested:** Earthing Electrode
3. **Serial Number:** GMAX-10 4. **Sample Code No.:** STDSST217S0841
5. **Type:** Earthing Electrode 5.1 **Designation:** Nil
6. **Drawing Number:** 50500710060617 (Drawing to be revised and verified)

7. **Rating of the Sample:**
 - 7.1 **Rated Voltage :-** 7.2 **Rated Frequency : 50 Hz**
 - 7.3 **No. of phases :-**
 - 7.5 **Rated short time current:** 40 kArms for one second.

8. **Sample tested for the following ratings:**
 - 8.1 **Short time current:** 40 kArms for one second.

- 9 **Type of test carried out:** Short time current test

- 10 **Specification followed:** As per customer's requirement
- 10.1 **Customer's requirement:** STC test to be conducted at 40 kArms for one second.

11 Test results:

Oscillogram No.	Short time current kArms R	Duration in second	Equivalent current for 1 second in kArms
S2170750.S02	40.53	1.0	40.53

Remarks No abnormality. Earthing Electrode found intact.


TEST ENGINEER


LABORATORY IN-CHARGE

This is only a provisional report. The final report alongwith drawings and other documents will be issued separately within one month from the date of test.

संयुक्त निदेशक
Director
संयुक्त अनुसंधान संस्थान
Central Power Research Institute
स्विचगियर परीक्षण तथा विकास केंद्र
Switchgear Testing & Development Station
गोविन्दपुरा, भोपाल - 462023
Govindpura, BHOPAL - 462023