



# Brilliant Engineering Works

ISO 9001:2008 Certified Company



[www.brilliantengineering.in](http://www.brilliantengineering.in)

[www.brilliantengineering.net](http://www.brilliantengineering.net)

email: [marketing@brilliantengineering.in](mailto:marketing@brilliantengineering.in)

## Stand Post Type Water Monitor:

Model no: BEW/026



## Technical Sprcifications:-

<b>MATERIALS</b>	
Body:	Stainless Steel
Seals:	PTFE Seals
Rotation sections:	Rotating machined bronze ball track with 140 set
	stainless steel ball bearings per rotation section.
<b>PERFORMANCE</b>	
Max. recommended working pressure:	15 bar
Test pressure:	22.5 bar
Traverse:	360° continuous
Elevation:	from 75° above to 45° below horizontal
<b>DIMENSIONS</b>	
Waterway:	80 mm
Mounting flange:	4" A.S.A. or as per demand
Outlet connection:	2 1/2 " B.S.P. male or as per demand
Maximum width:	490 mm
Maximum height:	700 mm
Maximum front to back:	590 mm (without nozzle)
Weight:	31 kg With Nozzle