



Brilliant Engineering Works

ISO 9001:2008 Certified Company



D/6 SAIKRIPA SOCIETY NETAJI NAGER HILL NO 3 OPP.SHARMA HIGH SCHOOL SAKINAKA MUMBAI 400072.

www.brilliantengineering.in

www.brilliantengineering.net

email: marketing@brilliantengineering.in

info@bewfire.com

TROLLEY MOUNTED FOAM/WATER MONITOR

TROLLEY MOUNTED FOAM MONITOR

HSN CODE. 84248990

MAKE- BRILLIANT

MODEL NO. BEW/FM-391



www.bewfire.com



Brilliant Engineering Works

ISO 9001:2008 Certified Company



D/6 SAIKRIPA SOCIETY NETAJI NAGER HILL NO 3 OPP.SHARMA HIGH SCHOOL SAKINAKA MUMBAI 400072.

www.brilliantengineering.in

www.brilliantengineering.net

email: marketing@brilliantengineering.in

info@bewfire.com



DETAIL OF WATER MONITOR IS:8442

SIZE INLETE 80MM OUTLET 63MM (MODEL NO. BEW/FM/391)



Brilliant Engineering Works

ISO 9001:2008 Certified Company



D/6 SAIKRIPA SOCIETY NETAJI NAGER HILL NO 3 OPP.SHARMA HIGH SCHOOL SAKINAKA MUMBAI 400072.

www.brilliantengineering.in

www.brilliantengineering.net

email: marketing@brilliantengineering.in

info@bewfire.com



BRILLIANT ENGINEERING WORKS
Manufacturer of Fire Fighting Equipments





The image shows a silver and black foam nozzle assembly. It consists of a main cylindrical body with a top cap and a handle. A blue braided hose is attached to the side. The nozzle is labeled 'AQUA FOAM NOZZLE' and 'BRILLIANT ENGINEERING WORKS'. The hose has a brass fitting at the end.

www.bewfire.com

Skype : gchauhan14

AQUA FOAM NOZZLE . JET 50 MTR FLOW 2500LPM

MOC. LIGHT WEIGHT AL HARD ANOZLED .



Brilliant Engineering Works

ISO 9001:2008 Certified Company



D/6 SAIKRIPA SOCIETY NETAJI NAGER HILL NO 3 OPP.SHARMA HIGH SCHOOL SAKINAKA MUMBAI 400072.

www.brilliantengineering.in

www.brilliantengineering.net

email: marketing@brilliantengineering.in

info@bewfire.com

DATA SHEET

1. NOMINAL BARREL SIZE . 63MM (2 1/2")
2. INLET . 63MM MALE INST/NRV/3/4
3. OUT LET . 63MM NOZZLE
4. MAXIMUM FLOW . 2500 LPM. (660 GPM)
5. VERTICAL ROTATION . -35DEGREE + 85 DEGREE
6. HORIZONTAL ROT. . 360 DEGREE
7. FOAM SUCTION . 3 % TO 6% BY CONTROL VALVE
8. PICK UP TUBE . 3 METR WITH STRAINER
9. BOTH ROATION. . MANUAL LOCK
10. WORKING PRESS. . 7.5 KG/CM²
11. TESTING PRESSURE. 32.0 KG/CM²
12. COLOR . FIRE RED.

www.bewfire.com www.brilliantengineering.in www.brilliantengineering.net