

+



Shaikh[®] Petroleum
An ISO 9001:2008 Certified Company

Certificate Of Analysis

Product Name : Burning Grade Furnace Oil

SR NO.	PARAMETER/ CHARACTERISTICS	TEST METHOD	SPECIFICATION LIMIT & UNIT	TEST RESULTS
1	DENSITY @ 15°C.	P 16	kg/m ³	955.2
2	FLASH POINT	P 21	Min. 66 CEL	72
3	KINEMATIC VISCOCITY @ 50°C.	P 25	Max 180.0 cSt	148
4	WATER CONTENT	P 40	Max 1.00%(V)	0.30
5	SULPHUR TOTAL	P33/XRF	Max. 4.00 WT%	2.100
6	GROSS CALORIFIC VALUE	P 7	kcl/kg	10270
7	POUR	P 10	Max.21 CEL	9

Office : Shaikh's : 11,12 & 13, Old Colony, Near Valia Crossing, G.I.D.C. Ind. Estate, Ankleshwar - 393 002.

Factory : Plot No. 615, GIDC Industrial Estate, Ankleshwar. • Ph. 02646 - 222479, 224207 Sales Ex. 27, Accounts Ex. 22

E-mail : accounts@shaikhpetro.com | sales@shaikhpetro.com | shaikhpetroleum@gmail.com • Web : www.shaikhpetro.com