

USER'S OPERATING MANUAL FOR PID DIGITAL TEMPERATURE CONTROLLER

(Models: AI 7481 / 7781 / 7981 / 7681 / 7881)



SPECIFICATIONS : -

1. DISPLAY TYPE

: Dual 4- Digit 7 segment LED
4 Digit Bright White (PV)
4 Digit Luminous Green (SV)

Model no.	AI-7481	AI-7781	AI-7981	AI-7681	AI-7881
Display height (PV)	0.36"	0.56"	0.80"	0.36"	0.36"
Display height (SV)	0.24"	0.39"	0.56"	0.36"	0.36"

STATUS LED'S

: OP 1 : Main Control Output

2. INPUT

Sensor input

: TC : J,K,R,S,N,T,B
RTD : Pt-100

Range

: Refer below table.

Sensor Type	Range	Resolution	Accuracy
Fe-k(J) T/C	0 ~ 760°C	1 °C	± 1 °C
Cr-AL(K) T/C	-99 ~ 1300°C	1 °C	
(R) T/C	0 ~ 1700°C	1 °C	
(S) T/C	0 ~ 1700°C	1 °C	
TC - N	-99 ~ 1300°C	1 °C	
TC - T	-99 ~ 400°C	1 °C	
TC - B	0 ~ 1800°C	1 °C	
Pt-100(RTD)	-100 ~ 450°C	1 °C	± 0.3 °C
Pt-100(RTD 0.1)	-99.9 ~ 450.0°C	0.1 °C	

Sampling Time

: 125 msec.

Resolution

: 1°C/0.1°C(Only for RTD)

CJC for TC

: Built in automatic

LWC for Pt-100

: Built in upto 18E max.

Digital Filter

: 1 to 10 Sec.

3. RELAY OUTPUT

Contact type

: N/O, CM, N/C

Contact Rating

: 5A @ 250VAC or 30 VDC

Life expectancy

: > 5,00,000 operations

Isolation

: Inherent

4. SSR DRIVE OUTPUT

Drive Capacity

: 12V @ 30mA.

Isolation

: Non-Isolated.

5. FUNCTION

Output 1

: Main Control output

Control Action

: ON-OFF/PID (Select)

Control Mode

: Heat/Cool (Select)

6. ENVIRONMENTAL

Operating Range

: 0 ~50°C, 5~90% Rh

Storage Humidity

: 95% Rh (Non-condensing)

7. POWER SUPPLY

Supply Voltage

: 90~270VAC, 50/60Hz.

Consumption

: 4W Maximum.

8. PHYSICAL

Housing

: ABS Plastic.

SAFETY INSTRUCTION :

This controller is meant for temperature control applications. It is important to read the manual prior to installing or commissioning of controller. All safety related instruction appearing in this manual must be followed to ensure safety of the operating personnel as well as the instrument.

GENERAL

- ❖ The controller must be configured correctly for intended operation. Incorrect configuration could result in damage to the equipment or the process under control or it may lead personnel injury.
- ❖ The controller is generally part of control panel and in such a case the terminals should not remain accessible to the user after installation.

MECHANICAL

- ❖ The Controller in its installed state must not come in close proximity to any corrosive/combustible gases, caustic vapors, oils, steam or any other process by-products.
- ❖ The Controller in its installed state should not be exposed to carbon dust, salt air, direct sunlight or radiant heat.
- ❖ Ambient temperature and relative humidity surrounding the controller must not exceed the maximum specified limit for proper operation of the controller.
- ❖ The controller in its installed state must be protected against excessive electrostatic or electromagnetic interferences. Ventilation holes provided on the chassis of the instrument are meant for thermal dissipation hence should not be obstructed in the panel.

ELECTRICAL

- ❖ The controller must be wired as per wiring diagram & it must comply with local electrical regulation.
- ❖ Care must be taken not to connect AC supplies to low voltage sensor input.
- ❖ Circuit breaker or mains s/w with fuse (275V/1A) must be installed between power supply and supply terminals to protect the controller from any possible damage due to high voltage surges of extended duration.
- ❖ Circuit breaker and appropriate fuses must be used for driving high voltage loads to protect the controller from any possible damage due to short circuit on loads.
- ❖ To minimize pickup of electrical noise, the wiring for low voltage DC and sensor input must be routed away from high current power cables. Where it is impractical to do this, use shielded ground at both ends.
- ❖ The controller should not be wired to a 3-Phase supply with unearthed star connection. Under fault condition such supply could rise above 264 VAC which will damage the controller.
- ❖ The Electrical noise generated by switching inductive loads might create momentary Fluctuation in display, alarm latch up, data loss or permanent damage to the instrument.
To reduce this use snubber circuit across the load.
- ❖ It is essential to install a over Temp. Protection device to avoid any failure of heating system. Apart from spoiling the product, this could damage the process being controlled.

⚠ CAUTION: To prevent the risk of electrical shock, switch off the power before making/removing any connection or removing the controller from its enclosure.

MECHANICAL INSTALLATION

The label on the controller identifies the serial number, wiring connections and batch number.

OVER ALL DIMENSIONS & PANEL CUT OUT (IN MM)

MODEL:-AI-7481/7781/7981




TABLE : 1

Dim Model	A	B	C	D	E	F	G	H
AI-7481	48	48	8	75	43	44	44	9
AI-7781	72	72	10	65	66	68	68	9
AI-7981	96	96	10	45	89	92	92	9
AI-7681	96	48	10	45	89	92	44	9
AI-7881	48	96	10	45	43	44	92	9


INSTALLATION GUIDELINES :

1. Prepare the cut-out with proper dimension as shown in Figure.
2. Remove clamp from controller
3. Push the controller through panel cut-out and secure the controller in its place by tightening the side clamp.


Model no.	AI-7481	AI-7781	AI-7981	AI-7681	AI-7881
Weight (gms.)	130	200	240	200	200

ELECTRICAL INSTALLATION :

The electrical connection diagram shown on the controller enclosure is as below.



FRONT PANEL LAYOUT




FRONT PANEL LAYOUT DESCRIPTION :

Sr.	NAME	FUNCTION
1	OP1 LED	Glows when OP1 is ON & flashes when delay time (dly1) is in operation(if selected mode is ON-OFF)
2	UPPER DISPLAY	It will display (1) Measured value of selected input or Error messages in run mode. (2) Parameters Value in program mode.
3	LOWER DISPLAY	It will display (1) SP (Main set point) / SP2 (Auxiliary/Alarm) set value / Set Soak time value/ balance or elapsed soak time in run mode. (2) Parameter code in program mode.
4	SET KEY	(1) For SP programming. (2) To access Control mode. (3) To access Configuration mode along with UP key. (4) To scroll the parameter & to store its value.
5	SHIFT KEY	(1) To increase/alter parameter value in program mode with Up / Dn Key. (2) Press for 3Sec in Programming this will help to go back to previous parameter.
6	UP KEY	(1) To increase/alter parameter value in program mode. (2) To Enter in configuration mode (with SET key) . (3) To acknowledge Alarm. (4) To enter in tune mode (with DOWN Key).
7	DOWN KEY	(1) To decrease / alter parameter value in program mode. (2) To enter in tune mode (with UP Key).

POWER UP :

At power on, following sequence will be prompted on the display for 1 sec. till it reaches to Home display mode.



PROGRAMMING

USER LIST : To access the user list press SET key once.

PARAMETER	LOWER DISPLAY	UPPER DISPLAY	RANGE	DESCRIPTION	DEFAULT
CONTROL SET POINT	SP	0	LSPL ~ HSPL	User can change SP value using UP/ DOWN keys. Holding the key, will change the value at a faster rate. Press SET key to store the desired value & move on to the next parameter.	0°C
RAMP RATE	rAtE	5.0	0.0 °C to 25.0 °C	This parameter will be available only if Enabled in Configuration List. User can set ramp rate/min for SP1 (Set Point) to minimize overshoot.	Disable

CONTROL LIST : To enter in this mode, press SET & DOWN key simultaneously for 3 sec. User can then set the control parameters.

PARAMETER	LOWER DISPLAY	UPPER DISPLAY	RANGE	DESCRIPTION	DEFAULT
LOCK CODE	LOCK	0	1 ~ 9999	Set this parameter to 15 (Default LOCK CODE) to access Control List. User has a choice to set different Lock Code via USER LOCK CODE in Config. List.	0
PROPORTIONAL BAND	Pb	5.0	0.5 to 99.9°C	This parameter will be prompted only if selected control action is PID. It sets bandwidth over which the output power is adjusted depending upon the error (SV-PV). The value of this parameter is automatically set by Auto tune function.	5.0°C
INTEGRAL TIME	Int	240	0 to 9999 Sec.	This parameter will be prompted only if selected control action is PID. It sets the time taken by PID algorithm to remove steady state error. The value of this parameter is automatically set by Auto tune function. If set to '0', this function will be disabled.	240
DERIVATIVE TIME	dt	60	0 to 300 Sec.	This parameter will be prompted only if selected control action is PID. It defines how strongly the controller will react to the rate of change of PV. The value of this parameter is automatically set by Auto tune function. If set to '0', this function will be disabled.	60
CYCLE TIME	CYCL	16.0	0.5 to 100.0 Sec.	This parameter will be prompted only if selected control action is PID. User can set this value based on process being controlled & type of output being selected. For Relay O/P, cycle time should be more than 12sec & for SSR O/P, cycle time should be less than 10sec.	16.0 Sec.
OUTPUT POWER LIMIT	OUTL	100.0	0.0 % TO 100.0 %	This parameter will be prompted only if selected control action is PID. This parameter will decide the Max. output power in % applied to the load.	100 %
TUNE OFFSET	t.OFS	100	50 % to 100 %	This parameter will be prompted only if selected control action is PID. This parameter allows the User to carry out Auto Tuning function below set point. (If tune offset is 50 %, tuning will be carried out at 50 % of set point and if 100 %, tuning will be carried out at 100% of the set point.)	100 %
CONTROL HYS	HYS	2	1 to 25 °C	This parameter will be prompted only if selected control action is ON-OFF. It sets the dead band between ON & OFF switching of the Output. Larger value of hysteresis minimize the number of ON-OFF operation to the load. This increases life of actuators like contactors but, also produces large errors (between PV & SV).	2°C
DELAY 1	dLY	0	0 to 500 Sec.	This parameter will be prompted only if selected control action is ON-OFF. It sets the main output restart time where O/P once turned off will turn ON only after restart time, regardless difference between PV & SP in Heat or Cool mode. If set to '0', O/P will be switched without delay. Also, Delay will be applicable in case of every power ON.	90 Sec.
OUTPUT OFF	OP.OF	dSbL	1 to 10	This parameter will be prompted only if selected control action is PID. With this parameter O/P will be Completely OFF after the Set Point + Offset Value. If Disable, O/P will act Depending upon the PID Value after Set Point achieved.	Disable

CONFIGURATION LIST : (1) To enter in this mode, press and hold SET & UP key simultaneously for 3 sec.
(2) Press UP or DOWN key to scroll between parameter options.
(3) Press SET key to store the current parameter & move on to the next parameter.

PARA METER	LOWER DISPLAY	UPPER DISPLAY	DESCRIPTION	DEFAULT																																	
LOCK CODE	LOCK	0	Set this parameter to 15 (Default LOCK CODE) to access Config. List. User has a choice to set different Lock Code via USER LOCK CODE in Config. List.	0																																	
INPUT TYPE	InPt	TC-J TC-P TC-r TC-S TC-n TC-t TC-b rtd rtd.i	<div>This parameter value is set according to the type of sensor (Thermocouple or RTD input) connected to the controller's input terminals.</div> <table><thead><tr><th>Sensor Type</th><th>Range</th><th>Resolution</th><th>Accuracy</th></tr></thead><tbody><tr><td>Fe-k(J) T/C</td><td>0 ~ 760°C</td><td>1 °C</td><td rowspan="7">± 1 °C</td></tr><tr><td>Cr-AL(K) T/C</td><td>-99 ~ 1300°C</td><td>1 °C</td></tr><tr><td>(R) T/C</td><td>0 ~ 1700°C</td><td>1 °C</td></tr><tr><td>(S) T/C</td><td>0 ~ 1700°C</td><td>1 °C</td></tr><tr><td>TC - N</td><td>-99 ~ 1300°C</td><td>1 °C</td></tr><tr><td>TC - T</td><td>-99 ~ 400°C</td><td>1 °C</td></tr><tr><td>TC - B</td><td>0 ~ 1800°C</td><td>1 °C</td></tr><tr><td>Pt-100(RTD)</td><td>-100 ~ 450°C</td><td>1 °C</td><td rowspan="2">± 0.3 °C</td></tr><tr><td>Pt-100(RTD 0.1)</td><td>-100.0 ~ 450.0°C</td><td>0.1 °C</td></tr></tbody></table>	Sensor Type	Range	Resolution	Accuracy	Fe-k(J) T/C	0 ~ 760°C	1 °C	± 1 °C	Cr-AL(K) T/C	-99 ~ 1300°C	1 °C	(R) T/C	0 ~ 1700°C	1 °C	(S) T/C	0 ~ 1700°C	1 °C	TC - N	-99 ~ 1300°C	1 °C	TC - T	-99 ~ 400°C	1 °C	TC - B	0 ~ 1800°C	1 °C	Pt-100(RTD)	-100 ~ 450°C	1 °C	± 0.3 °C	Pt-100(RTD 0.1)	-100.0 ~ 450.0°C	0.1 °C	TC - J
Sensor Type	Range	Resolution	Accuracy																																		
Fe-k(J) T/C	0 ~ 760°C	1 °C	± 1 °C																																		
Cr-AL(K) T/C	-99 ~ 1300°C	1 °C																																			
(R) T/C	0 ~ 1700°C	1 °C																																			
(S) T/C	0 ~ 1700°C	1 °C																																			
TC - N	-99 ~ 1300°C	1 °C																																			
TC - T	-99 ~ 400°C	1 °C																																			
TC - B	0 ~ 1800°C	1 °C																																			
Pt-100(RTD)	-100 ~ 450°C	1 °C	± 0.3 °C																																		
Pt-100(RTD 0.1)	-100.0 ~ 450.0°C	0.1 °C																																			
LOWER SET POINT LIMIT	LSPL	0	Sets the minimum limit for set point adjustment. It can be set from minimum specified range of selected sensor to HSPL value.	0 °C																																	
HIGHER SET POINT LIMIT	HSPL	400	Sets the maximum limit for set point adjustment. It can be set from LSPL value to maximum specified range of selected sensor.	400 °C																																	
PROCESS VALUE OFFSET	OFSt	0	Function of this parameter is to add/subtract a constant value to the measured PV to obtain Final PV for control applications. This parameter value needs to be altered for one of the following reason : (i) To compensate for known thermal gradient. (ii) To match the display values with another recorder or indicator measuring the same PV.	0 °C																																	
INPUT FILTER	FLtr	1	Controller is equipped with an adaptive digital filter which is used to filter out any extraneous pulses on the PV. Filtered PV Value is used for all PV dependent functions. If PV signal is fluctuating due to noise, increase the filter time constant value.	4																																	
CONTROL MODE FOR O/P 1	mode	PId OnOF	User can select between PID or ON-OFF action algorithm to be adopted for output.	PID																																	
CONTROL LOGIC FOR O/P	OP IL	HEAT COOL	<div>This parameter will be prompted only if selected control mode is ON-OFF. User can select heating logic in which OP1 will remain ON till PV < SP. (PV increases when output is ON.)</div> <div>This parameter will be prompted only if selected control mode is ON-OFF. User can select cooling logic in which OP1 will remain ON till PV > SP. (PV decreases when output is ON.)</div>	HEAT																																	

PARAMETER	LOWER DISPLAY	UPPER DISPLAY	DESCRIPTION	DEFAULT
OUTPUT TYPE	OPty	RLY ▼ ▲ SSR	User has to set this parameter very carefully in accordance with the output used. (Separate terminal for RELAY & SSR, Refer electrical installation) Select Relay if LOAD is connected via contactor. Whenever user selects Relay, Cycle time will automatically get set to 16 sec. User can modify cycle time via control list. Select SSR if LOAD is connected via SSR (DC voltage pulses). Whenever user selects SSR, Cycle time will automatically get set to 1sec. User can modify cycle time via control list.	RELAY
OVERSHOOT CONTROL POINT	OCP	dSbL	This parameter will be prompted only if selected control action is PID. Setting this parameter on higher side will proportionally slows down the rate of rise of PV to minimize overshoot(this may cause delay to reach SP). Setting on lower side will proportionally or disabling this parameter will increase the rate of rise of PV(which may cause overshoot). Disable this option if delay is not required to reach SP.	DISABLE
RAMP RATE	rAtE	EnbL ▼ ▲ dSbL	This parameter will be prompted only if OCP (over shoot control point) is disabled. When enabled, User can set the desired RAMP rate in USER list. When disabled, this parameter will not be prompted in USER list.	Disable
LOWER DISPLAY MESSAGE	LdSP	tOCL ▼ ▲ t-SP ▼ ▲ r-SP	This parameter will be prompted only if RATE (Ramp Rate) is Enabled. By pressing DOWN key, Lower display will Toggle between Actual Set point Value i.e. Target Set Point (T-SP) & Ramping Set point (R-SP). By this parameter Lower display will only show the Target Set Point T-SP Value. By this parameter Lower display will only show the Ramping Set Point R-SP.	Toggle
AUTO TUNE	tunE	EnbL ▼ ▲ dSbL	This parameter will be prompted only if selected control action is PID. If Enabled, this parameter will be prompted if user press Up & Down keys Simultaneously for 3Sec. If Disabled, this parameter will not be prompted if user press Up & Down keys Simultaneously for 3Sec.	Enable
SET POINT 1	SP	EnbL ▼ ▲ dSbL	If Enabled, User can View & edit the Set point in USER list. If disabled, User can only View the Set Point but Can not edit it in USER list.	Enable
USER LOCK CODE	ULOC	15	Default USER LOCK CODE is 15 to access Control & Configuration List. User has a choice to set its own USER LOCK CODE between 1 to 9999, this is to prevent unauthorized access of Control & Configuration List.	15

AUTO TUNING MODE : To enter in this mode, Press & hold SHIFT key for minimum 3 sec.

PARAMETER	LOWER DISPLAY	UPPER DISPLAY	DESCRIPTION	DEFAULT
AUTO TUNING MODE	tunE	nO ▼ ▲ yES	This function will be executed only if selected control action is PID & Auto tune is Enable. Auto-tuning function can be initiated by setting this parameter to 'YES'. The decimal of LSB flashes till Auto Tuning function is in progress. During Auto-tuning, Controller learns the process characteristics by itself & calculates required P, I & D values. User can cancel or abort this feature by setting this parameter to 'NO'.	NO

USER GUIDE :

ON-OFF ACTION : In this mode, Output (Relay/SSR) remains ON till actual temperature reaches to the set point value. On reaching SP, Output turns OFF & remains OFF till actual temperature drops down (in Heat logic) or raises (in Cool logic) equal to hysteresis set by User. (As shown in Fig : 3.1 & 3.2)




Fig: 3.1




Fig: 3.2

AUTO TUNING MODE : In this mode, Controller learns the process characteristics by itself and calculates the required P,I & D values. It can be performed at any time after power ON but, it is best to start it when the process is at Ambient temperature in order to minimize overshoot & undershoot. Auto tuning is applied in case of :

- (1) Initial set up for a new process.
- (2) Substantial change in SP from previous auto tuning value.
- (3) Control accuracy is not satisfactory.

If the control performance by using auto-tuning is still unsatisfactory, User can apply the further adjustments of P,I & D values as shown below

Adjust	Symptom	Solution
Proportional Band	Slow Response	Decrease PB
	Over Shoot or Oscillations	Increase PB
Integral Time	Slow Response	Decrease Int
	Instability or Oscillation	Increase Int
Derivative Time	Slow Response or Oscillation	Decrease Dt
	High Over Shoot	Increase Dt

ABBREVIATION : C.A. : Control Action
CJC : Cold junction compensation
CM : Common terminal of relay
LWC : Lead wire (Length) compensation

NC : Normally Close terminal of Relay
NO : Normally Open terminal of Relay
OP1 : Output 1
PV : Process Value (actual temp.)

SP : Set Point Value(set temp.)
SSR : Solid State Relay
T/C : Thermocouple



Mfgd by: Innovative Instruments & Controls LLP

413, New Sonal Link Service Industrial Premises Co-op Society Ltd,
Building No.2, Link Road, Malad (W), Mumbai - 400064.
Tel: 022-66939916/17/18;
E-mail : sales@itherm.co.in
Website : www.itherm.co.in