



भारत सरकार
GOVERNMENT OF INDIA
उपभोक्ता मामले, खाद्य एवं सार्वजनिक वितरण मंत्रालय
Ministry of Consumer Affairs, Food & Public Distribution
उपभोक्ता मामले विभाग
Department of Consumer Affairs
राष्ट्रीय परीक्षण शाला (उ०क्षे०)
NATIONAL TEST HOUSE (NR)
कमला नेहरु नगर, गाजियाबाद KAMLA NEHRU NAGAR, GHAZIABAD-201002
Phone : 0120-2789813, 2789906 Fax : 0120-2789883 E-mail : nthnr@rediffmail.com

Sample No. ME/01868 TEST CERTIFICATE

Issued to: Aman Engineering Works **Date:** 08/6/2009
File No. NTH/NR/ME/2008/88
C-54 & 55, Focal Point Extension, Jalandhar -144004
Ref. No. Nil
Dated: 06-11-2008 and further correspondence
Dated 10-11-2008,03-12-08& 05-03-09
Sample Recd on 01-12-2008
One sample consisting of three water meters described as "15 mm single Jet class B of KRANTI MAKE having meter numbers 444626,469936 and 470445
As desired, the above meters were subjected to Type Test as per IS: 779-1994 read with IS: 6784-1996. The results obtained are noted below:-

Tests Results	Observed value	Specified value
Meter Number		
	444626	469936
		470445
A Performance		
1 Minimum starting flow at which measurement starts	satisfactory	Satisfactory
	Satisfactory	Satisfactory
	Satisfactory	Satisfactory
2 Pressure tightness test		
2.1 At 1.6 MPa for 15 minutes	satisfactory	Satisfactory
	Satisfactory	Satisfactory
2.2 At 2.0 MPa for 1 minutes	satisfactory	Satisfactory
	Satisfactory	Satisfactory
3 Loss of pressure in MPa		
3.1 For nominal flow rate (Qn: 1500l/h)	0.020	0.020
	0.020	0.020
3.2 For maximum flow rate (Qmax: 3000 l/h)	0.085	0.085
	0.085	0.085
4 Metering Accuracy		
4.1 Error in metering accuracy at maximum flow rate (Qmax : 3000l/h)	+ 1.0%	+ 0.9%
		+ 1.4%
		+/- 2% Max

Note : 1. This test certificate or reports may not be published for commercial purpose, except in full unless permission for the publication of an approved abstract has been obtained from the DIRECTOR, NATIONAL TEST HOUSE.



NTH/NR/ME/2008/88

309276

Tests Rerults	Observed value	Specified value
	Meter Number	
	444626	469936
	444626	470445
4.2 Error in metering accuracy at normal flow rate (Qn: 1500l/h)	± 1.1%	± 0.5%
4.3 Error in metering accuracy at transitional flow rate (Qt: 120 l/h)	0.0%	-1.0%
4.4 Error in metering accuracy at minimum flow rate (Q min :30 l/h)	-1.0%	+3.0%
5. Performance after Life test (Accelerated endurance test as per clause 12.4.4) conducted on two meters bearing no 444626 and 470445	Meter No	
	444626	470445
5.1 Minimum starting flow at Which measurements starts	Satisfactory	Satisfactory
5.2 Pressure tightness test		
5.2.1 At 1.6 MPa for 15 minutes	Satisfactory	Satisfactory
5.2.2 At 2.0 MPa for 1 minute	Satisfactory	Satisfactory
5.3 Loss of pressure in MPa		
5.3.1 For nominal flow rate (Qn: 1500l/h)	0.020	0.020
5.3.2 For maximum flow rate (Qmax: 3000l/h)	0.080	0.080
5.4 Meeting accuracy		
5.4.1 Error in meeting Accuracy at maximum Flow rate (Qmax :3000l/h)	-1.0%	-1.0%
		+/- 2% Max



NTH/NR/ME/2008/88

Meter No

	444626	470445	469936	470445
5.4.2 Error in meeting Accuracy at normal Flow rate (Qn : 1500 l/h)	+ 0.4%	+ 0.9%		+/-2% Max
5.4.3 Error in metering Accuracy at transitional flow rate (Qt : 120 l/h)	-1.0%	-1.0%		+/-2% Max
5.4.4 Error in metering Accuracy at minimum Flow rate (Q min.: 30l/h)	-1.0%	-3.0%		+/-5% Max
6- Performance after Temperature suitability test (As per clause 10.3)				
Two meters, one after initial performance test and other after life test were subjected to temperature suitability test				
6.1 Minimum starting flow at which measurements starts	Satisfactory	Satisfactory		Shall start registering at a Flow rate of 30 l/h
6.2 Pressure tightness test	Satisfactory	Satisfactory		No leakage seepage or deformation
6.2.1 At 1.6 MPa for 15 minutes	Satisfactory	Satisfactory		No leakage seepage or deformation
6.2.2 At 2.0 MPa for 15 minutes	Satisfactory	Satisfactory		No leakage seepage or deformation
6.3 Loss of pressure in MPa				
6.3.1 For nominal flow rate (Qn 1500l/h)	0.020	0.085		0.025 Max
6.3.2 For maximum flow rate (Qmax 3000 l/h)	0.020	0.085		0.100 Max
6.4 Metering Accuracy				
6.4.1 Error in metering accuracy at maximum flow rate (Qmax : 3000l/h)	0.2%	1.0%		+/-2% Max
6.4.2 Error in metering Accuracy at normal Flow rate (Qn : 1500 l/h)	1.0%	0.9%		+/-2% Max
6.4.3 Error in metering Accuracy at transitional flow rate (Qt : 120 l/h)	0.5%	1.0%		+/-2% Max
6.4.4 Error in metering Accuracy at minimum Flow rate (Q min.: 30l/h)	3.0%	3.0%		+/-5% Max

[Handwritten signature]



NTH/NR/ME/2008/88

309276

Meters size, threads, and dimensions (in mm)
(Notations as per Table 2 of IS: 779-1994)

7.1	Meter size	15
7.2	Threads	G3/4B
7.3	Length of threads, on one side other side	15 10 Min
7.4	Length of meter with nipples	248
7.5	Length of meter without Nipples	109
7.6	Width (W)	70
7.7	Height (H1)	13
7.8	Height (H2)	61
8	Value of verification Scale interval (I)	0.1 0.2 Max

Note: The samples were tested at factory site on 12.03.2009 and 17.03.2009

Remarks:- The sample meets the requirements of IS: 779-1994 in respect of test carried out for water meter (Domestic type) of size 15 mm, single jet and class "B".

Tested By

Checked By

Approved By

(ANIL CHOPRA)
SCIENTIST SB(Mech)

(R.N.RAM)
SCIENTIST SC(Mech)

(SHER SINGH)
SCIENTIST SD