



भारत सरकार
GOVERNMENT OF INDIA
उपभोक्ता मामले, खाद्य एवं सार्वजनिक वितरण मंत्रालय

Ministry of Consumer Affairs, Food & Public Distribution

Department of Consumer Affairs

राष्ट्रीय परीक्षण शाला (उ०क्षे०)

NATIONAL TEST HOUSE (NR)

कमला नेहरू नगर, गाजियाबाद KAMLA NEHRU NAGAR, GHAZIABAD-201002

Phone : 0120-2789813, 2789906 Fax : 0120-2789883 E-mail : nthnr@rediffmail.com

TEST CERTIFICATE

Sample No. ME/01868

Issued to: Aman Engineering Works
C-54 & 55, Focal Point Extension,
Jalandhar - 144004

Date: ०८.६.२००९

Ref. No. Nil

Dated: 06-11-2008 and further correspondence

Dated: 10-11-2008, 03-12-08 & 05-03-09

Sample Recd on 01-12-2008

One sample consisting of three water meters described as " 20 mm Multi Jet class B of KRANTI MAKE having meter numbers 269462,269461 & and 269463


As desired, the above meters were subjected to Type Test as per IS: 779-1994 read with IS: 6784-1996 . The results obtained are noted below:-;

Tests Results		Observed value	Specified value
		Meter Number	
A	Performance		
1	Minimum starting flow at which measurement starts	Satisfactory	Satisfactory
2	Pressure tightness test		
2.1	At 1.6 MPa for 15 minutes	Satisfactory	Satisfactory
2.2	At 2.0 MPa for 1 minutes	Satisfactory	Satisfactory
3	Loss of pressure in MPa		
3.1	For nominal flow rate (Qn: 2500l/h)	0.020	0.020
3.2	For maximum flow rate (Qmax: 5000 l/h)	0.065	0.065
4	Metering Accuracy		
4.1	Error in metering accuracy at maximum flow rate (Qmax : 5000l/h)	- 0.6 %	- 1.5 %
			+ 0.7 %
			+/- 2% Max

Page 1 of 4

Note : 1. This test certificate or reports may not be published for commercial purpose except in full unless permission for the publication of an approved abstract has been obtained from the DIRECTOR, NATIONAL TEST HOUSE.

 NTH/NR/ME/2008/88-B			
<p align="center">Tests Results</p>			
<p>4.1 Error in metering accuracy at normal flow rate (Qn: 2500l/h)</p>	Observed value Meter Number 269462	Specified value +0.0% -1.0% +/- 0.5% Max	269461 269463 +/- 2% Max
<p>4.2 Error in metering accuracy at transitional flow rate (Qt: 200 l/h)</p>	Observed value Meter Number 269462	Specified value +1.0% -2.0% +/- 2% Max	269461 269463 +/- 2% Max
<p>4.3 Error in metering accuracy at minimum flow rate (Qt: 200 l/h)</p>	Observed value Meter Number 269462	Specified value +2.0% -2.0% +/- 2% Max	269461 269463 +/- 2% Max
<p>4.4 Error in metering accuracy at maximum flow rate (Q min :50 l/h)</p>	Observed value Meter Number 269462	Specified value +2.0% -2.0% +/- 5% Max	269461 269463 +/- 5% Max
<p align="center">Performance after Life test(Accelerated endurance test as per clause 12.4.4) conducted on two meters bearing no 269461 and 269463</p>			
<p>5.1 Minimum starting flow at which measurements starts</p>	Meter No. 269461	Satisfactory	Satisfactory
<p>5.2 Pressure tightness test</p>	Meter No. 269463	Satisfactory	Shall start registering at a flows rate of 50 l/h
<p>5.2.1 At 1.6 MPa for 15 minutes</p>	Meter No. 269461	Satisfactory	No leakage seepage or deformation
<p>5.2.2 At 2.0 MPa for 1 minute</p>	Meter No. 269463	Satisfactory	No leakage seepage or deformation
<p>5.3 Loss of pressure in MPa</p>	Meter No. 269461	0.015	0.025 Max
<p>5.3.1 For nominal flow rate (Qn: 2500l/h)</p>	Meter No. 269463	0.015	0.100 Max
<p>5.3.2 For maximum flow rate (Qmax: 5000l/h)</p>	Meter No. 269461	0.075	0.100 Max
<p>5.4 Metering accuracy</p>	Meter No. 269463	-0.2%	+/- 2% Max
<p align="right"><i>[Signature]</i></p>			
<p align="right">Page 2 of 4</p>			



NTH/NR/ME/2008/88-B

Meter No

5.4.2	Error in metering Accuracy at normal Flow rate (Qn : 2500 l/h)	- 0.5%	- 0.7%	+/-2% Max
5.4.3	Error in metering Accuracy at transitional flow rate (Qt : 200 l/h)	+ 0.5%	+ 0.5%	+/-2% Max
5.4.4.	Error in metering Accuracy at minimum Flow rate (Q min.: 50 l/h)	+4.0%	+4.0%	+/-5% Max

6- Performance after Temperature suitability test (As per clause 10.3)
Two meters, one after initial performance test and other after life test were subjected to temperature suitability test

Meter No.

6.1	Minimum starting flow at which measurements starts	Satisfactory	Satisfactory	Shall start registering at a Flow rate of 50 l/h
6.2	Pressure tightness test	Satisfactory	Satisfactory	No leakage seepage or deformation
6.2.1	At 1.6 MPa for 15 minutes	Satisfactory	Satisfactory	No leakage seepage or deformation
6.2.2	At 2.0 MPa for 15 minutes	Satisfactory	Satisfactory	No leakage seepage or deformation
6.3	Loss of pressure in MPa			
6.3.1	For nominal flow rate (Qn 2500l/h)	0.015	0.015	0.025 Max
6.3.2	For maximum flow rate (Qmax 5000 l/h)	0.080	0.080	0.100 Max
6.4	Metering Accuracy			
6.4.1	Error in metering accuracy at maximum flow rate (Qmax : 5000l/h)	0.0%	-0.5%	+/-2% Max
6.4.2	Error in meeting Accuracy at normal Flow rate (Qn : 2500 l/h)	-0.5%	-0.2%	+/-2% Max
6.4.3	Error in metering Accuracy at transitional flow rate (Qt : 200 l/h)	-1.0%	+1.0%	+/-2% Max
6.4.4.	Error in metering Accuracy at minimum Flow rate (Q min.: 50 l/h)	-2.0%	+4.0%	+/-5% Max



NTH/NR/ME/2008/88-B

Meters size, threads, and dimensions (in mm) (Notations as per Table 2 of IS: 779-1994)	
7.1 Meter size	20 mm
7.2 Threads	Satisfactory
7.3 Length of threads, on one side other side	15
7.4 Length of meter with nipples	290
7.5 Length of meter without Nipples	+0
7.6 Width (W)	85
7.7 Height (H1)	36
7.8 Height (H2)	72
8 Value of verification	0.1
Scale interval (I)	0.2 Max

Note:- The samples were tested at factory site on 1.12.2008, 16.03.2009 and 17.03.2009

Remarks:- The sample meets the requirements of IS: 779-1994 in respect of test carried out for water meter (Domestic type), of size 20 mm, Multi jet and class "B".

Tested By

(ANIL CHOPRA)

SCIENTIST SB(Mech)

Checked By

(R.N. RAM)

SCIENTIST SC(Mech)

Approved By

(SHER SINGH)

SCIENTIST SD