



Declaration of Performance


DOP-No. ArmaProtect EXPS

1. Unique identification code of the product-type:	ArmaProtect EXPS	
2. Intended use/es:	Fire stopping and sealing products for penetration seals	
3. Manufacturer:	Armacell GmbH Robert-Bosch-Str. 10 D-48153 Münster	 Phone +49 (0) 251 / 76 03-0  Fax +49 (0) 251 / 76 03-448 info.de@armacell.com www.armacell.com
4. System for assessing and verifying constancy of performance	AVCP 1	
5. European Assessment Document:	EAD 350454-00-1104	
European Technical Assessment:	ETA-21/1025 (2024/03/06)	
Technical Assessment Body:	ETA-Danmark A/S	
Notified body/ies:	MPA Braunschweig (No. 0761)	
EC- Certificate of constancy of performance	0761-CPR-1239	

Essential characteristics	Performance
Mechanical resistance and stability (BWR 1)	
NPD	NPD
Safety in case of fire (BWR 2)	
Reaction to fire	Class E: EN 13501-1
Fire resistance	Maximum Class EI 120 (EN 13501-2)
Hygiene, health and environment (BWR 3)	
Air permeability	NPD
Water permeability	NPD
Content, emission and/or release of dangerous substances	No dangerous substances
Safety and accessibility (BWR 4)	
c	NPD
Adhesion	NPD
Durability and serviceability	Use category type X
Protection against noise (BWR 5)	
Airborne sound insulation	NPD
Energy economy and heat retention (BWR 6)	
Thermal properties	NPD
Water vapour permeability/ Water vapour diffusion resistance	NPD
Sustainable use of natural resources (BWR 7)	
NPD	NPD

The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 3.

Signed for and on behalf of the manufacturer by:
Dr.-Ing. Elke Rieß, Manager Central Technical Marketing
Münster, 02.10.2024



.....
 [signature]

This declaration of performance is made available in accordance with Article 7(3) of Regulation (EU) No 305/2011 on our homepage: <http://www.armacell.com/DoP>.