



SIMATIC HMI connection box compact for Mobile Panels, installation in control cabinet, PROFINET and PROFI-safe, connection of safety relay, Connection point detection

General information	
Product type designation	Connection box
Product function	
• Web-based management	No
FH technology	
Safety evaluation through direct wiring	
• Reconnection without emergency stop circuit interruption	No
• Reconnection with emergency stop circuit interruption	Yes
• Monitoring the STOP button	Yes
• Monitoring of emergency stop button	Yes
• Monitoring of acknowledgement button	Yes
Safety evaluation via PROFI-safe	
• Reconnection without emergency stop circuit interruption	Yes
• Reconnection with emergency stop circuit interruption	No
• Monitoring the STOP button	Yes
• Monitoring of emergency stop button	Yes
• Monitoring of acknowledgement button	Yes
Installation type/mounting	
Wall mounting/direct mounting	No
Control cabinet installation	Yes
Supply voltage	
Type of supply voltage	DC
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Input current	
Current consumption (rated value)	18 mA
Starting current inrush I^2t	0.003 A ² ·s
Power	
Active power input, typ.	0.43 W
Interfaces	
Number of industrial Ethernet interfaces	2
Number of PROFINET interfaces	2
Connection point identification	Yes
Industrial Ethernet	
• Industrial Ethernet status LED	0
Protocols	
PROFINET	Yes; No switch functionality
IRT	No
PROFI-safe	Yes; No switch functionality

EtherNet/IP	Yes
AS-Interface	No
EIB/KNX	No
Protocols (Ethernet)	
• TCP/IP	Yes; No switch functionality
• DHCP	No
• SNMP	No
• DCP	No
• LLDP	No
Redundancy mode	
Media redundancy	
— MRP	No
Further protocols	
• MODBUS	Yes
• other bus systems	No
EMC	
Emission of radio interference acc. to EN 55 011	
• Limit class A, for use in industrial areas	Yes; EN 61000-6-4, interference emission: Intended for use in industrial areas.
• Limit class B, for use in residential areas	No
Degree and class of protection	
IP (at the front)	IP65
IP (rear)	IP20
Standards, approvals, certificates	
CE mark	Yes
cULus	Yes
RCM (formerly C-TICK)	Yes
KC approval	No; in preparation
Suitable for safety functions	Yes
Highest safety class achievable in safety mode	
• Performance level according to ISO 13849-1	PLe
• SIL acc. to IEC 61508	SIL 3
Use in hazardous areas	
• ATEX Zone 2	No
• ATEX Zone 22	No
• cULus Class I Zone 1	No
• cULus Class I Zone 2, Division 2	No
• FM Class I Division 2	No
Marine approval	
• Germanischer Lloyd (GL)	Yes
• American Bureau of Shipping (ABS)	Yes
• Bureau Veritas (BV)	Yes
• Det Norske Veritas (DNV)	Yes
• Korean Register of Shipping (KRS)	Yes
• Lloyds Register of Shipping (LRS)	Yes
• Nippon Kaiji Kyokai (Class NK)	Yes
• Polski Rejestr Statkow (PRS)	No
• Chinese Classification Society (CCS)	Yes
Ambient conditions	
Ambient temperature during operation	
• min.	0 °C
• max.	55 °C
Relative humidity	
• Operation, max.	90 %
configuration / header	
Configuration software	
• STEP 7 Professional (TIA Portal)	No
• WinCC Comfort (TIA Portal)	No
• WinCC Advanced (TIA Portal)	No
• WinCC Professional (TIA Portal)	No
Mechanics/material	

Enclosure material (front)	
• Plastic	Yes
• Aluminum	No
• Stainless steel	No

Dimensions	
Width	96 mm
Height	125 mm
Depth	77.9 mm
Mounting cutout, width	78 mm
Mounting cutout, height	107 mm
Overall depth	30 mm

Weights	
Weight (without packaging)	0.25 kg
Weight (with packaging)	0.29 kg

Other	
Usable in the following products	
• Product 1	6AV2125-*

Classifications			
		Version	Classification
	eClass	14	27-33-02-92
	eClass	12	27-33-02-92
	eClass	9.1	27-33-02-92
	eClass	9	27-33-02-92
	eClass	8	27-24-92-03
	eClass	7.1	27-24-92-03
	eClass	6	27-24-92-03
	ETIM	9	EC002584
	ETIM	8	EC002584
	ETIM	7	EC002584
	IDEA	4	3552
	UNSPSC	15	32-15-17-03

Approvals / Certificates		
General Product Approval	Test Certificates	other

[Confirmation](#)



EG-Konf.



[Special Test Certificate](#)

[Miscellaneous](#)

other	Environment
-------	-------------

[Confirmation](#)

[Miscellaneous](#)

Siemens
EcoTech



[Environmental Confirmations](#)

last modified:

2/4/2025