Certificate no: Page 1 of 2 HDR 1458001/02



Project:

Client: Foamtech Antifire Company

Office: Hardwar

Client's Order Number: Request For Services signed by Client

Date: 30 January 2014

Order Status: Complete

Inspection Dates

First: 06 January 2014

Final: 30 January 2014

This certificate is issued to FOAMTECH ANTIFIRE COMPANY, Hardwar to certify that at their request, the undersigned surveyor to Lloyds Register Asia did select samples of Foamer Brand High Expansion Foam 3 % from Batch no. HX/EN/ISO/03/01/12/13 for the purpose of confirming that the properties were in accordance with EN 1568-2: 2001

## Details of tests:

 $Temperature\ conditioning\ of\ foam\ concentrates\ as\ per\ Clause\ E.3\ (Annex\ E\ of\ EN\ 1568-2):$ 

No stratification or non-homogeneity could be detected in the sample.

Sediment (Annex C of EN 1568-2):

Before ageing of the sample : 0.02% After ageing of the sample : 0.03% (24 hours at 60°C)

Viscosity at 20°C : 2.58cSt

pH of the concentrate at 20°C : 7.46

Surface Tension, Interfacial Tension and Spreading coefficient (Annex F of EN 1568-2) By Ring method:

	Surface Tension (Dynes/cm)	Interfacial Tension (Dynes/cm)	Spreading coefficient (Dynes/cm)
Before conditioning:	: 18.9	3.4	3.7
After High temperature conditioning at 60°C	for 7 days followed by 2 days	at 20°C:	
Top Sample	: 19.0	3.5	3.5
Bottom Sample	: 19.1	3.4	3.5

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

## Expansion and Drainage (Annex G of EN 1568-2):

Before conditioning of the sample

Potable Water

Sea water

Expansion ratio

: 523 3 min 38 seconds 510 3 min 00 seconds

25% drainage time 50% drainage time

: 6 min 12 seconds

5 min 22 seconds

After conditioning of the sample in accordance with Annex E of EN 1568-2:

P	'n	ta	h	le	wa	ter

Sea water

		Top
xpansion ratio	:	510

Bottom 530

Top 502

Bottom 504

25% drainage time 50% drainage time

: 3 min 35 seconds 6 min 16 seconds

3 min 32 seconds 6 min 08 seconds

2 min 58 seconds 5 min 07 seconds 3min 07 seconds 5min 16 seconds

Fire Tests (Annex H of EN 1568-2) - Outdoor Test:

Fire tests carried out in accordance with Annex H1 and H2 using

Potable water and Sea water:-

Preburn time

: 45 seconds

Foam application

: 120 seconds

Fire Tray

: 1.73 m<sup>2</sup>

Fuel

: Commercial Heptane on water bed.

90% control time 99% control time	0.00/	control	tima
99% control time	2141104	omies me annough	
	99%	control	time

Potable water 70 seconds Air Temp

76 seconds 78 seconds 82 seconds 85 seconds 16°C 15°C 16°C 16°C

Water Temp Fuel Temp Foam Temp Wind Speed (m/sec)

15°C 16°C 0.1

16°C 16°C 0.1

Sea water

71 seconds

Conclusion: The mentioned tests were witnessed by the Surveyor and the results obtained were observed within the limits of the requirements of EN 1568-2: 2001.

Remarks: This Certificate stands valid till 30 January 2016.

Hardwar Lloyd's Register Asia

GAGANDEEP SINGH Surveyor to Lloyd's Register Asia

A subsidiary of Lloyd's Register Group Limited